

LOCATION 811 S CHESTER ST.

CITY East.

BETWEEN Garrison Blvd.

STREET &amp; - TENTH ST.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	71'		5-5-97	
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	63'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"	PRESSURE 60 PSI	INCHES W.C.	LOCATION 292' from (C) OF Garrison Blvd
----------------	-----------------	-------------	---


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY A.H.J.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION West side of S CHESTER.

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY