

LOCATION 843' S CHESTER ST. CITY CAS.

BETWEEN TENTH ST. STREET & PARRISON PLUD. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>59'</u>		<u>5-8-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>53'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 143' FROM @ OF

TENTH ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: FT. _____ IN. _____ LOCATION West side of S Chester St.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY