

LOCATION 843 1/2 S CHESTER ST. CITY EAST.

BETWEEN Tenth St. STREET & GARRISON BLVD STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P. | 29' | | 5 - | 5 - 57 |
| MAIN TO PROP. LINE | " | " | 16' | | | |
| PROP. LINE TO BLDG. | " | " | 13' | | | |

ENTERS: SAME BRANCHED INTO: 843 S CHESTER

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 163' From (C) of

Tenth St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.f

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Westside of S Chester St.

"A" P/S READING 9 TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



| Test Station | | |
|--------------------------------------------|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY