

LOCATION 845 S CHESTER. CITY Gast.

BETWEEN GARRISON BLVD STREET & Tenth St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	56'		5-	9-97
MAIN TO PROP. LINE	"	"	5'			
PROP. LINE TO BLDG.	"	"	51'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 93' from C of Tenth Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DNF

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION West side of York

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY