

LOCATION 1613 Chesterfield Ct

CITY Los Angeles

BETWEEN Belmar Dr.

STREET &

STREET

	SIZE	TYPE	P	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4		3	163	Red Dresser 7-15-94		
MAIN TO PROP. LINE	3/4		3	41			
PROP. LINE TO BLDG.	3/4		0	122			

ENTERS: 1613

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Sisk House


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By [Signature]

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 16' NDC St

"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Pro Dresser was bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY