

LOCATION 1619 Chesterfield CT CITY Crofton
BETWEEN Belmar DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>57 1/2"</u>	<u>P</u>	<u>77'</u>	<u>10-29-01</u>		
MAIN TO PROP LINE	<u>57 1/2"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>57 1/2"</u>	<u>P</u>	<u>72'</u>			

ENTERS 1619 BRANCHED INTO
TAP SIZE 40 PRESSURE 60 PSI INCHES W C LOCATION 382' w. of center of Belmar DR.

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.
MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED
DEPTH 3 FT 0 IN LOCATION 43' S. of center of Chesterfield CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

