

LOCATION 207 & 209 S. Chestnut St. CITY CASTONIA  
BETWEEN Franklin Blvd. STREET & Second Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>1-10-94</u>	<u>26' Existing</u>	<u>3/4 C/W</u>
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 207 & 209 same buildings BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 100 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 260' N of Co of Second Ave

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993


DEPTH: 3 Ft. 0 In. LOCATION 18' W of Co of Chestnut St.

"A" P/S READING P TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tied Tracer - wire OFF AT Tee

Bare Main Replacement

Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser</u> <u>.90</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY