

LOCATION 519 N. ChestnutCITY BASTONIABETWEEN HARRISONSTREET & LINCOLN

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	20'	9/26/94		
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4"		55'			

ENTERS: 519

BRANCHED INTO:


TAP SIZE: 1/2"PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION North side of 519PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1991DEPTH: 1 Ft. 6 In. LOCATION North side of 517"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 903304

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY