

LOCATION 827 ChestnutCITY GASTONIABETWEEN 9TH

STREET &amp;

GARRISON

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>117</u>			<u>11/24/97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>41</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>76</u>			

ENTERS:


BRANCHED INTO:

TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION 294 feet N. of 9thPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY NSMAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL X PLASTIC  YEAR INSTALLED 1966DEPTH: 3 FT. IN. LOCATION 14' E of c of chestnut"A" P/S READING 1.1TOTAL ANODES 1#  17# L.R. # 

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY