

LOCATION 907 CHessnut CITY GASTONIA
BETWEEN 9TH STREET & GARRISON STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <u>8'</u>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>100</u>		<u>11-24-97</u>	
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>35</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>"</u>	<u>65</u>			

ENTERS: 907 BRANCHED INTO: 0
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 16' EAST of CHessnut

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY NS
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1966
DEPTH: 3 FT. _____ IN. LOCATION 16' EAST of CHessnut

"A" P/S READING 1.1 TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY