

LOCATION 4584 Chestnut Lane CITY GASTONIA
BETWEEN MOUNTAIN OAK LN. STREET & End of Caldesack on Chestnut Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>315'</u>	<u>8-1-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>25'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>290'</u>			

ENTERS: 4584 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 600 P.S.I. _____ INCHES W.C. LOCATION 143' S of Co of Mountain Oak Ln.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 3 Ft. 0 In. LOCATION 12' E of Co of Chestnut Ln.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rises Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY