

LOCATION 109 China Berry Ct. CITY Boston MA
 BETWEEN SPLIT OAK TR. STREET & Cypress Dr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 5/8" | P | 74' | 3-27-02 | | |
| MAIN TO PROP LINE | 5/8" | P | 10' | " | | |
| PROP LINE TO BLDG | 5/8" | D | 64' | " | | |

ENTERS 109 BRANCHED INTO 0
 TAP SIZE 3/4" PRESSURE 100 PSI INCHES W C LOCATION 317' East


PRESSURE TEST @ 100 PSI FOR 14 HRS BY N. Woods
center of split oak tr.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH 3' FT 6" IN LOCATION 26' south of center of cold ASAC
China Berry Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 6 L.R. # 00000532

REMARKS new Plastic service



| Test Station | | |
|--|------|----------------|
| Reading & Location | Lead | Valis |
| P/S Pipeline Lead - Red New Service | S | <u>Plastic</u> |
| P/S Pipeline Lead - White Existing Main | E | <u>1.60</u> |