

LOCATION 109 W. Church CITY GASTONIA
BETWEEN DAVIS STREET & AIRLINE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8</u>	<u>P</u>	<u>80'</u>	<u>6-25-02</u>	<u>31'</u>	
MAIN TO PROP LINE	<u>5/8</u>	<u>P</u>	<u>2'</u>			
PROP LINE TO BLDG	<u>5/8</u>	<u>P</u>	<u>78'</u>			

ENTERS 109 BRANCHED INTO -
TAP SIZE 3/8 PRESSURE 60 PSI _____ INCHES W C LOCATION _____


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SE

MAIN-SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1972

DEPTH 2 FT 0 IN LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 17 LR # -

REMARKS
Used Existing 3/4 Stub - 40' clw Pipe
Tied on to 4" MAIN - Bonded to CP 2885
Stub Bonded to 4" MAIN



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Ri's on</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	