

LOCATION 401 S. Church

CITY Gastonia

BETWEEN Edwards

STREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	C+W	85' Existing	4-9-94		
MAIN TO PROP. LINE			Transition Fitting	2 Dresser	used to tie-over	
PROP. LINE TO BLDG.				to 2" Plastic		

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 65 S. of Edwards


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 18 East of Church

"A" P/S READING 1.6 TOTAL ANODES 1* 1 17* L.R. #

REMARKS: Tracer wire not Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S R.	1.6
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY