

LOCATION 919 Church St.CITY GASTONIABETWEEN GARRISONSTREET & E 9th

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|----------|---------|
| MAIN TO BLDG. | 2" | P | 44' | 1-5-98 | 1-5-98 | |
| MAIN TO PROP. LINE | 2" | P | 30' | | 25' 3/4" | |
| PROP. LINE TO BLDG. | 2" | P | 14' | | etcw | |

ENTERS: 919


BRANCHED INTO:

TAP SIZE: 3/8PRESSURE 60 PSI

INCHES W.C.

LOCATION 15' S OF E 9thPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M ParkerMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1962DEPTH: 3 FT. 0 IN. LOCATION 79' west of church st"A" P/S READING 1.5TOTAL ANODES 1# 17# L.R. #

REMARKS:



| Test Station | | |
|--|------|---------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P-RISEK |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY