

LOCATION 1427 Church Hill CITY GAstonia

BETWEEN Buckingham Ave. STREET & Sterling STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Cfw</u>	<u>10'</u>	<u>8-30-94</u>	<u>20' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 Cfw to Relocate Service</u>	
PROP. LINE TO BLDG.					<u>Outside OF Fence.</u>	

ENTERS: 1427 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 250' N of Cor of Buckingham Ave.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1965

DEPTH: Ft. In. LOCATION

"A" P/S READING 1.0 TOTAL ANODES 1 # 17 # L.R. #

REMARKS: Relocated 3/4 Cfw Service out Side of Fence because of Dog.
Bonded Dresser. Inst. 1st Anode on Service
Tested New 10' Section 15. Min



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.0
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY