

LOCATION 1411 CIRCLE DR.CITY GASTONIABETWEEN BEVERLYSTREET & OAKDALE

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>55'</u>		<u>6-25-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>50'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION W. SIDE OF 1411PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.MAIN-SIZE 2"

C.I. _____

BARE STEEL _____

COATED STEEL _____

PLASTIC ☒YEAR INSTALLED 97DEPTH: 4 FT.


IN.

LOCATION SOUTH SIDE OF CIRCLE"A" P/S READING N/A

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New ServiceSPP/S Pipeline Lead - White
Existing MainE

ENG. DEPT. USE ONLY