

LOCATION 345 Claudette Dr. CITY GASTONIA  
BETWEEN Lyon STREET & Fallswood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>105'</u>	<u>9-22-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>55'</u>			

ENTERS: 345 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 25' W of C of Lyon


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1970

DEPTH: 2' FT. 6 IN. LOCATION 17' N of C of Claudette

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 624224

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY

310 01 077 121  
3745