

LOCATION 509 S. Clay St. CITY GASTONIA
 BETWEEN HARVIE ST STREET & FOURTH AVE. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	60'	8-19-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	55'			

ENTERS: 509 BRANCHED INTO:
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 87' N. of center of
HARVIE AVE.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFSTEADT
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991
 DEPTH: 3 Ft. 0 In. LOCATION 15' W. of center of S. Clay St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 412116

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY