

LOCATION 505 + 507 Clinton DrCITY GASTONIA

BETWEEN

Fairfield Dr

STREET &amp;

Fairfield Dr

STREET

	SIZE	TYPE	LENGTH	INSTALLED <del>7/2 over</del>	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Cxw Plastic</u>	<u>93'</u> <u>4'</u>	<u>6/4/94</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: 505 + 507

BRANCHED INTO:

TAP SIZE: <u>1/2"</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>South side of 505</u> <u>East side of 507</u>
-----------------------	---------------------------	-------------	--

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC      YEAR INSTALLED 1994DEPTH: 3 Ft.      In. LOCATION West side of Clinton Dr"A" P/S READING .50 TOTAL ANODES 1\* 0 17\* 0 L.R. #     

REMARKS: Tied over 93' of 2x 3/4" Cxw service to 505 with 4' of 3/4" Plastic  
56' of 2x 3/4" Plastic service to 507, split with 505. (Ex 3/4" Ins Jumped)  
The .50 P.S Reading was taken before Anode Installed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>505</u> <u>R</u>	<u>1.10</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY