

LOCATION

908 Cloister Dr

CITY

GASTONIA

BETWEEN

Augusta Ct.

STREET &

End of Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	PLASTIC	110'	6-17-96		
MAIN TO PROP. LINE	3/4	PLASTIC	15'			
PROP. LINE TO BLDG.	3/4	PLASTIC	95'			

ENTERS:

908

BRANCHED INTO: 0

TAP SIZE:

1/2

PRESSURE

60

PSI

INCHES W.C.

LOCATION

237' E of Cloister Augusta St.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

RL

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1989

DEPTH:

3

FT.

0

IN.

LOCATION

45' N of Cloister Dr Culdesack.

"A" P/S READING

PLASTIC N/A

TOTAL ANODES 1#

0


17#

0

L.R. #

325093

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

Riser
PLASTICP/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY