

LOCATION 925 cloister DR CITY GASTONIA

BETWEEN Augusta Ct STREET & STREET

|                     | SIZE | TYPE    | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|---------|--------|-----------|---------|---------|
| MAIN TO BLDG.       | 3/4" | plastic | 77'    | 12/5/97   |         |         |
| MAIN TO PROP. LINE  | 3/4" |         | 15'    |           |         |         |
| PROP. LINE TO BLDG. | 3/4" |         | 62'    |           |         |         |

ENTERS: 925 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION East side of 925


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DP

MAIN-SIZE 2' C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1990

DEPTH: 3 FT. 0 IN. LOCATION South side of cloister DR.

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 2 L.R. # 810677

REMARKS:



| Test Station                               |          |       |
|--|----------|-------|
| Reading & Location                         | Lead     | Volts |
| P/S Pipeline Lead - Red<br>New Service     | <b>S</b> |       |
| P/S Pipeline Lead - White<br>Existing Main | <b>E</b> |       |

ENG. DEPT. USE ONLY