

LOCATION 966 Cloister Dr.CITY GastoniaBETWEEN SawgrassSTREET & Sherwood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	130'	1-24-94		
MAIN TO PROP. LINE	3/4	P	40'			
PROP. LINE TO BLDG.	3/4	P	90'			

ENTERS: 966BRANCHED INTO: 0TAP SIZE: 1/2

PRESSURE

60


P.S.I.

INCHES W.C.

LOCATION

N. Side of 966PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1989DEPTH: 3 Ft.      In. LOCATION 21' W of C of Cloister"A" P/S READING plastic TOTAL ANODES 1\*      17\*      L.R. #     

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY