

LOCATION 541 EAST CLUB CITY CAS
BETWEEN Franklin Blvd STREET & Green Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>146</u>		<u>1-</u>	<u>12-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>142</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 271' From E of Franklin Blvd

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY _____
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 FT. 0 IN. LOCATION E. OF EAST CLUB

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY