

LOCATION 439 E Club Circle Dr. CITY Gastonia

BETWEEN Franklin Blvd STREET & Green Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	103'	3-10-97		
MAIN TO PROP. LINE	3/4"	P	30			
PROP. LINE TO BLDG.	3/4"	P	73'			

ENTERS: 439 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 1085' NW. of center of Franklin Blvd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S.G.

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1968

DEPTH: 3 FT. 0 IN. LOCATION 12' NE of center of E. Club Cir

"A" P/S READING .7 TOTAL ANODES 1# 0 17# ϕ L.R. # 132105

REMARKS:



Test Station		
Reading & Location ~	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY