

LOCATION 2620 E ClubCITY GASTONIABETWEEN Ruby

STREET &amp;

Thomas

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	ctw		TIED OVER 4-16-94		
MAIN TO PROP. LINE				110' 3/4"	1/11	
PROP. LINE TO BLDG.				ctw		

ENTERS: 4620BRANCHED INTO: 1-17-99TAP SIZE: 1/2

PRESSURE

60


P.S.I.

INCHES W.C.

LOCATION

12' N OFClubPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC x YEAR INSTALLED 90DEPTH: 3 Ft. 0 In.LOCATION 21' W OF Ruby"A" P/S READING 1.3TOTAL ANODES 1\* 1 17\*     L.R. #     

REMARKS:

INS Bonded solid

## Test Station

## ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.3 ctw Riser
P/S Pipeline Lead - White Existing Main	E	