


LOCATION 2708 Club Dr. CITY Gastonia
 BETWEEN Armstrong Pk. Rd. STREET & Thomas Trl. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>5</u>	<u>126'</u>	<u>1969</u>	<u>10-9-01</u>	<u>10-9-01</u>
MAIN TO PROP LINE	<u>3/4"</u>	<u>5</u>	<u>0'</u>		<u>retired</u>	<u>relocated</u>
PROP LINE TO BLDG	<u>3/4"</u>	<u>5</u>	<u>126'</u>		<u>40'</u>	<u>8 Ft</u>

 ENTERS 2708 BRANCHED INTO 0
 TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 273' west
gr. center of Armstrong Pk. Rd.
 PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY DW
 MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969
 DEPTH 2' FT 0" IN LOCATION 113' north of center of Club Dr.
 "A" P/S READING L.I. TOTAL ANODES I# 0 17# 0 LR # 0
 REMARKS relocated 8' of c.w. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	