

LOCATION 3626 W. Club Colony CITY GASTONIA
BETWEEN SHERWOOD CIRCLE STREET & Cul-de-sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>42</u>	<u>8-22-01</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>3</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>39</u>			

ENTERS

BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION N. side of house


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GL

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 2001

DEPTH 3 FT IN LOCATION E. side of Club Colony

"A" P/S READING N/A TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	