

LOCATION

602 Clyde St

CITY

Gastonia

BETWEEN

Wood

STREET &amp;

Gilman

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	72		3-	31-98
MAIN TO PROP. LINE	1/2	1/2	32'			
PROP. LINE TO BLDG.	1/2	1/2	40			

ENTERS:

602

BRANCHED INTO:

-

TAP SIZE:

3/4

PRESSURE

60

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @

100

PSI

FOR

1 1/4

HRS.

BY

SE

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1958

DEPTH:

3 FT. 0

IN.

LOCATION

"A" P/S READING

PL


TOTAL ANODES 1#

17#

L.R. #

-

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	Riser	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY