

LOCATION 605 Clyde St. CITY GASTONIA  
BETWEEN Gilmer St. STREET & Wood St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>58'</u>	<u>3-25-98</u>	<u>50' 3/4 Existing CFW Pipe to</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>3'</u>		<u>Be Retired w/main</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>55'</u>			


ENTERS: 605 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 271' 5" E of Wood St.

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 15' E of C of Clyde St.

"A" P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

ENG. DEPT. USE ONLY