

LOCATION 606 + 604 Clyde St CITY EASTONIA  
BETWEEN Gilmer STREET & Wood STREET

	SIZE	TYPE	LENGTH <u>606</u>		INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>129'</u>	<u>30'</u>	<u>3-25-98</u>	<u>231' Existing</u>	<u>3/4" to be Retired</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>37'</u>	<u>10'</u>		<u>w/main on 606</u>	<u>56' Existing</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>92'</u>	<u>20'</u>		<u>3/4" to be Retired</u>	<u>w/main on 604</u>

ENTERS: 606 BRANCHED INTO: 604  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 270' S of C of Wood St


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 4 FT. 0 IN. LOCATION 15' E of C of Clyde St

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY