

LOCATION 607 Clyde St. CITY GASTONIA
BETWEEN Gilmer STREET & Wood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>65'</u>	<u>3-28-98</u>	<u>84' Existing 1" Bare</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>		<u>Pipe to Be Retired</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>		<u>w/main.</u>	

ENTERS: 607 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 315' N of Co of Gilmer St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 17" E of Co of Clyde St.

"A" P/S READING Plastic N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY