

LOCATION 609 Clyde St. CITY Exigtonia
 BETWEEN Gilmer St. STREET & Wood St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	54'	12-29-99		
MAIN TO PROP LINE	3/4"	P	4'			
PROP. LINE TO BLDG	3/4"	P	50'			

ENTERS: Same BRANCHED INTO _____

TAP SIZE: 1/2 PRESSURE 60# PSI _____ INCHES W.C. LOCATION 14' South of Clyde St
221' East of Gilmer


PRESSURE TEST @ 100# PSI FOR 1/4 HRS BY B. Ballard

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH. 4 FT 0 IN LOCATION 14' South of Clyde

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS Installed New Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	P.R. 1.20
P/S Pipeline Lead White Existing Main	E	