

LOCATION 625 Clyde St CITY GASTONIA  
BETWEEN GILMER STREET & HUDSON STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>60' EXIST</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>3' NEW</u>	<u>3-31-98</u>		
PROP. LINE TO BLDG.			<u>3/4" P</u>			


ENTERS: 625 BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 421 W OF Gilmer

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY M PARKER  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 98

DEPTH: 3 FT. 0 IN. LOCATION 24' SOUTH OF Clyde St

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RISER</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY