

LOCATION	3416 Clydesdale CT.			CITY	GASTON, N.C.	
BETWEEN	Apploosa Way			STREET &	STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	105'	12-21-93		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	65'			

ENTERS: 3416 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 40 P.S.I. INCHES W.C. LOCATION 235' N. of center of Apploosa Way


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffpelt

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1984

DEPTH: 3 Ft. In. LOCATION 21' W. of center of Clydesdale

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 506546

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY