

LOCATION 1101 Colony Ct CITY GASTONIA
BETWEEN RAVENHILL DR STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>87'</u>	<u>11-14-95</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>83'</u>			

ENTERS: 1101 BRANCHED INTO: —
TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 25' W. of C of Colony Ct


PRESSURE TEST: @ 100 psi For 1/9 Hrs. By JP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1974

DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING 1.10 TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY