

LOCATION 3008 Colony Ridge Dr.

CITY GASTONIA

BETWEEN Liberty OAK

STREET &amp; HOFFMAN Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	122'	9-14-96		
MAIN TO PROP. LINE	3/4	Plastic	44'			
PROP. LINE TO BLDG.	3/4	Plastic	78'			

ENTERS: 3008

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60

P.S.I.

INCHES W.C.

LOCATION 93' N of C of Liberty  
OAK Ct.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In.

LOCATION

"A" P/S READING Riser Plastic TOTAL ANODES 1# 0 17# 0 L.R. # 510445

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	