

LOCATION	3014 Colony Ridge Dr		CITY	Gastonia	
BETWEEN	Hoffman Rd	STREET &	Liberty Oak Ct	STREET	

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	118'	5-2-96		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	73'			

ENTERS: 3014 BRANCHED INTO:

TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 141' N- of center of Liberty Oak Ct.
---------------	--------------------	-------------	---


PRESSURE TEST: @ 105 psi For 1/4 Hrs. By S. Huffsteth

MAIN-SIZE 2"	C.I. <input type="checkbox"/>	BARE STEEL <input type="checkbox"/>	COATED STEEL <input type="checkbox"/>	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1994
--------------	-------------------------------	-------------------------------------	---------------------------------------	---	---------------------

DEPTH: 3 Ft. 0 In. LOCATION 20' W. of center of Colony Ridge Dr

"A" P/S READING P	TOTAL ANODES 1# 0 17# 0	L.R. # 211660
-------------------	-------------------------	---------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY