

LOCATION 3026 Colony Ridge CITY CASTANIA
BETWEEN Pensbury STREET & Liberty Ridge STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>119'</u>	<u>11/17/95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>46'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>73'</u>			

ENTERS: 3026 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION South side of 3026

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 3 Ft. 0 In. LOCATION West side of Colony Ridge

"A" P/S READING 0 TOTAL ANODES 1* 0 17* 0 L.R. # 0013348

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY