

LOCATION 3033 Colony Ridge CITY GASTONIA  
BETWEEN Pensbury STREET & Liberty STREET oak


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	83'	1/12/95		
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4"		68'			

ENTERS: 3033 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION South side of 3033

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 Ft. 0 In. 6 LOCATION West side of Colony Ridge

"A" P/S READING 0 TOTAL ANODES 1\* 0 17\* 0 L.R. # 013348

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY