

LOCATION 3044 Colony Ridge Dr.

CITY GASTONIA

BETWEEN Trailwood

STREET &amp; Brushy Ln.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	130	2-10-96		
MAIN TO PROP. LINE	3/4	Plastic	51			
PROP. LINE TO BLDG.	3/4	Plastic	79			

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 57 North of

Trailwood


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC / YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 21 West of Colony Ridge

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY