


LOCATION 3045 Colony Ridge Dr.CITY GASTONIABETWEEN Pensbury Ct.STREET & Trailwood Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plast	105'	10-17-94		
MAIN TO PROP. LINE	3/4	Plast	5'	10-17-94		
PROP. LINE TO BLDG.	3/4	Plast	100'	10-17-94		

ENTERS: 3045BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 87' S of C of Pensbury Ct.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R.L.MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 19' W of C of Colony Ridge Dr."A" P/S READING Plastic TOTAL ANODES 1* _____ 17* _____ L.R. # 467047

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic Riser
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY