

LOCATION 3062 Colony Ridge dr CITY Gastonia
BETWEEN Trad ct. STREET & Dead End STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|-------------|-----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>P</u> | <u>112'</u> | <u>11-11-96</u> | | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>43'</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>69</u> | | | |

ENTERS: 3062

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 20' w. of c of
Colony Ridge dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: _____



| Test Station | | |
|--|----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>R</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY