

LOCATION 3063 Colony Ridge Dr. CITY CANTONIA

BETWEEN Traid Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>91'</u>			
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>86'</u>			

ENTERS: 3063 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION 15' S. of center of

Traid Ct


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUSTON

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 21' W. of center of Colony Ridge Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 27573

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY