

LOCATION 3081 Colony Ridge Dr.

CITY Gastonia

BETWEEN Trail Dr.

STREET & End OF Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	120'	9-16-94		
MAIN TO PROP. LINE	3/4	Plastic	8'			
PROP. LINE TO BLDG.	3/4	Plastic	112'			

ENTERS: 3081

BRANCHED INTO: O

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 520' S of Trail Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 5' E of Colony Ridge Dr.

"A" P/S READING Plastic TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY