

LOCATION 614 Colorado Ct. CITY GASTONIA

BETWEEN MONTANA DR STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>98'</u>	<u>5-11-99</u>		
MAIN TO PROP LINE	<u>2 1/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>88'</u>			

ENTERS 614 BRANCHED INTO.

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 183' W. of center of MONTANA DR

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 18' N. of center of Colorado Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 364774

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

