

LOCATION 220 S ColumbiaCITY GreshamBETWEEN 2NDSTREET & Franklin

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CW</u>	<u>(51' EXIST)</u>	<u>TIED OVER</u>		
MAIN TO PROP. LINE			<u>3/4" CW</u>	<u>4-17-95</u>		
PROP. LINE TO BLDG.						

ENTERS: 220

BRANCHED INTO:

TAP SIZE: 1/2PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 15' W OFS ColumbiaPRESSURE TEST: @ 100 psi For 4 Hrs. By M ParkerMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In. LOCATION 120' N OF E 2ND"A" P/S READING .95 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>.95 CW RISE</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY