

LOCATION 305 S ColumbiaCITY GASTONIABETWEEN 2ndSTREET & 3rd

STREET

	SIZE	TYPE	LENGTH	TIED OVER INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>(75 TIED OVER)</u>	<u>5-7-93</u> <u>75' 3/4"</u>		
MAIN TO PROP. LINE				<u>CW 01.8 1990</u>		
PROP. LINE TO BLDG.						

ENTERS: 305

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

60


P.S.I.

INCHES W.C.

LOCATION

17' W OF S ColumbiaPRESSURE TEST: @ 100 psi For 1/4 Hrs. By M ParkerMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1994DEPTH: 3 Ft. 0 In.LOCATION 148' south of E 2nd"A" P/S READING 1.1TOTAL ANODES 1* 1 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.1 CW</u> <u>RISEK</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY