

LOCATION 307 S Columbia

CITY GASTONIA

BETWEEN 2nd

STREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	61' 3/4 en	TIED OVER 5-1-95		
MAIN TO PROP. LINE			TIED OVER	orig ins		
PROP. LINE TO BLDG.				1980		

ENTERS: 307

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 17' W OF Columbia


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By M PARKER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 94

DEPTH: 3 Ft. 0 In. LOCATION 196" South of 2nd

"A" P/S READING 1.2 TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	1.2 3/4 ctwiser
P/S Pipeline Lead - White Existing Main	E	