

LOCATION 311-315-317 S. ColumbiaCITY Gaslowie

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>20'</u>	<u>4-29-95</u>	<u>Tied over 2' 2' 3/4 P. Sew.</u>	
MAIN TO PROP. LINE					<u>to 2' P. Main</u>	
PROP. LINE TO BLDG.						

ENTERS: 315BRANCHED INTO: 311, 317TAP SIZE: 1/2

PRESSURE

P.S.I.


INCHES W.C.

LOCATION

1/2' W. of Caf
S. Columbia &PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SPMAIN-SIZE 2"C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In.

LOCATION

"A" P/S READING

PTOTAL ANODES 1* 17* L.R. # REMARKS: 311, 315 P. Riser 317 C/W Riser

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u> </u>	<u>317</u> <u>1.200</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY